



**CITY OF SUGAR LAND**  
Permits & Inspections Department

**BUILDING - E PERMIT APPLICATION**

APPLICATION # \_\_\_\_\_

PROJECT ADDRESS: \_\_\_\_\_

PROJECT NAME/OWNER: \_\_\_\_\_

ELECTRICAL COMPANY NAME: \_\_\_\_\_ PHONE:(     ) \_\_\_\_\_

\_\_\_\_\_ ADDRESS CITY/STATE ZIP

MASTER ELECTRICIAN'S NAME: \_\_\_\_\_ LICENSE #: \_\_\_\_\_

JOB DESCRIPTION: \_\_\_\_\_

<u>ITEMS</u>	<u>COST</u>	<u>QUANTITY</u>	<u>TOTAL</u>
METER LOOP & SERVICE: UP TO AND INCLUDING 50 KW	16.50		
OVER 50KW THROUGH 250 KW	16.50		
OVER 250 KW	33.00		
TCI – MUST ALSO SELECT ML&S ABOVE <b>(LETTER REQUIRED)</b>	33.00		
ELECTRICAL SERVICE UNDER GROUND	16.50		
TEMPORARY SAW POLE	22.00		
RECONNECTION FEE	33.00		
ELECTRICAL PANEL REPLACEMENT *also select Reconnect	22.00		
SUB PANEL with 8 OR MORE CIRCUITS (ea)	8.75		
ELECTRIC HEAT: UP TO AND INCLUDING 1 KW	8.75		
1 KW THROUGH 10 KW	8.75		
OVER 10 KW (\$8.75 for 1 <sup>st</sup> 10KW plus 2.00 per kw over 10)		Total KW	
MOTORS: UP TO AND INCLUDING 1 HP	5.50		
OVER 1HP through 10 HP	8.50		
OVER 10HP (\$8.75 for 1 <sup>st</sup> 10HP plus 2.00 per HP over 10)		Total HP	
TRANSFORMERS: UP TO AND INCLUDING 1 KVA	2.00		
OVER 1 KVA through 10 KVA	8.75		
OVER 10 KVA (\$8.75 for 1 <sup>st</sup> 10 KVA plus 2.00 per KVA over 10)		Total KVA	

<u>ITEMS</u>	<u>COST</u>	<u>QUANTITY</u>	<u>TOTAL</u>
OUTLETS	1.00		
LIGHTING FIXTURES	1.00		
RANGE RECEPTACLE	5.50		
CLOTHES DRYER	5.50		
WATER HEATERS	8.75		
COOKING TOPS	5.50		
OVENS	5.50		
GARBAGE DISPOSALS	5.50		
DISHWASHERS	5.50		
MISCELLANEOUS	22.00		
MOTION PICTURE/COMMERCIAL SOUND EQUIPMENT	8.75		
X-RAY MACHINES	8.75		
BALL PARK & PARKING LOT LIGHT POLES (EACH)	33.00		
POLE WITH GUY WIRE (EACH)	8.75		
SIGN CIRCUIT	8.75		
<b>BASE PERMIT FEE</b>	<b>33.00</b>		<b>33.00</b>

PAY BY ESCROW ACCOUNT  TOTAL DUE \$ \_\_\_\_\_

**ELECTRICAL CODE AMENDMENTS:**

The City of Sugar Land has adopted the 2014 edition of the National Electrical Code with the following amendments:

1. No conductor smaller than No. 12 shall be used in a wiring system.
2. Conductor Material – Conductors shall be of copperclad aluminum, copper or aluminum is sizes 1/0 or larger, unless otherwise stated.
3. The following regulations apply to underground installations:
  - (1) All conductors operating at fifty (50) volts or more shall be installed in conduit.
  - (2) Ridged nonmetallic conduit shall be limited to schedule 40 when below grade and schedule 80 when exposed to physical damage.

Code amendments may be found at [www.sugarlandtx.gov/DevCodeCh7](http://www.sugarlandtx.gov/DevCodeCh7)

I hereby certify that I have read and examined this document and know the same to be true and correct. All provisions of laws and ordinances governing this type work will be compiled with whether specified herein or not. Granting of a permit does not presume to give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction.

\_\_\_\_\_  
**APPLICANT SIGNATURE**

\_\_\_\_\_  
**DATE**